

Table of Detected Contaminants

Organic Contaminants Found at Entry Point

Contaminant	Water Source	Violation Yes / No	Date(s) of Sampling	Average Level found (Range)	Units Measured	MCLG	Regulatory Limit (MCL, TT, or AL)	Likely Source of Contamination
Dissolved Organic Carbon	Otisco	No	Monthly 2014	2.1 (1.8 -2.7)	mg/l	N/A	N/A	Naturally occurring.
	Ontario	No	Monthly 2014	1.7 (1.3 -2.2)	mg/l	N/A	N/A	
Total Organic Carbon	Otisco	No	Monthly 2014	2.0 (1.7 - 2.4)	mg/l	N/A	N/A	Naturally occurring.
	Ontario	No	Monthly 2014	1.6 (1.2 -2.0)	mg/l	N/A	N/A	
Total Trihalo Methanes	Ontario	No	Monthly 2014	12.6 (8.5 - 18)	ug/l	N/A	80	By-product of drinking water chlorination. TTHM's form when source water contains large amounts of organic matter.
Haloacetic acids	Ontario	No	Jul & Aug 2013	6.35 (6.3 - 6.4)	ug/l	N/A	80	By-product of drinking water chlorination.