

Table of Detected Contaminants

Organic Contaminants Found at Entry Point

Contaminant	Water Source	Violation Yes / No	Date(s) of Sampling	Average Level found (Range)	Units Measured	MCLG	Regulatory Limit (MCL, TT, or AL)	Likely Source of Contamination
Di(2-ethylhexyl) phthalate (DEHP)	Skaneateles	No	May 2016	0.79	ug/l	0	6	Used plastic products such as polyvinyl chloride, plastic toys, vinyl upholstery, adhesives and coatings. Compound likely to be released to the environment during production and waste disposal of these products. Also used in inks, pesticides, cosmetics, and vacuum pump oil.
Dissolved Organic Carbon	Otisco	No	Monthly 2016	2.5 (1.89 -3.58)	mg/l	N/A	N/A	Naturally occurring.
	Ontario	No	Monthly 2016	1.6 (nd -2.4)	mg/l	N/A	N/A	
Total Organic Carbon	Otisco	No	Monthly 2016	2.3 (1.97- 2.99)	mg/l	N/A	N/A	Naturally occurring.
	Ontario	No	Monthly 2016	1.7 (1.1 -2.3)	mg/l	N/A	N/A	
Total Trihalo Methanes	Ontario	No	Monthly 2014	12.6 (8.5 - 18)	ug/l	N/A	80	By-product of drinking water chlorination. TTHM's form when source water contains large amounts of organic matter.
Haloacetic acids	Ontario	No	Jul & Aug 2013	6.35 (6.3 - 6.4)	ug/l	N/A	80	By-product of drinking water chlorination.

Radionuclides Found at Entry Point

Contaminant	Water Source	Violation Yes / No	Composite of quarterly samples	Level found	Units Measured	MCLG	Regulatory Limit (MCL, TT, or AL)	Likely Source of Contamination
Total Uranium	Ontario	No	Feb, May, Aug, Nov. 2016	0.29	ug/l	N/A	30	Erosion of natural deposits.