

## Table of Detected Contaminants

### Bacteria Found in the Distribution System

Contaminant	Sample Source	Violation Yes/ No	Date(s) of Sampling in 2021	Month with Highest % positive samples	Units Measured	MCLG	Regulatory Limit (MCL, TT, or AL)	Likely Source of Contamination
Total Coliform Bacteria*	OCWA Distribution System	No	approx. 70 per week	November 0.28 % (1 out of 352)	N/A	0	> 5 % Positive samples in any month	Naturally present in the environment

\*Whenever a positive sample for total coliform is found, the sample is further tested for the presence of E.coli, plus three additional resamples are collected. OCWA regularly samples about 70 sites per week located throughout our distribution system. We test these sites for both bacteria and disinfectant residual to make sure our water is of a safe and sanitary quality.

### Disinfectant & Disinfection By-products Found in the Distribution System

Contaminant	Sample Source	Violation Yes/ No	Date(s) of Sampling in 2021	Level found (Range)**	Units Measured	MCLG	Regulatory Limit (MCL, TT, AL, or MRDL)	Likely Source of Contamination
Chlorine Residual	OCWA Distribution System	No	approx. 70 per week	0.58 (ND - 1.36)	mg/l	N/A (MRDLG)	4 (MRDL)	Added to water to kill harmful bacteria and to prevent the regrowth of bacteria
Chlorite	OCWA Distribution System	No	Monthly; April to November	0.16 (< 0.01 - 0.25)	mg/l	N/A	1	By-product of drinking water disinfection at plant using chlorine dioxide.
Total Trihalo Methanes ***	OCWA Distribution System	No	Quarterly; Feb, May Aug, Dec	46.54 (15.90 - 77.10)	ug/l	N/A	80	By-product of drinking water chlorination. TTHM's form when source water contains large amounts of organic matter.
Haloacetic Acids****	OCWA Distribution System	No	Quarterly; Feb, May Aug, Dec	17.39 (6.60 - 34.00)	ug/l	N/A	60	By-product of drinking water chlorination.

**Disinfection by-products:** During disinfection, certain by-products form as a result of chlorine reacting with naturally occurring organic matter. The disinfection process is carefully monitored so that disinfection is effective, while levels of disinfection by-products are kept low. Trihalomethanes (THM's) and Haloacetic acids (HAA's) are classes of chemicals that OCWA is required to monitor in its distribution system.

\*\* The reported "Level Found" for trihalomethanes and haloacetic acids is the highest recorded quarterly running annual average among all of OCWA's disinfection by-product sampling locations

\*\*\* See 'Terms & Abbreviations' for the listing of trihalomethanes contaminants

\*\*\*\* See 'Terms & Abbreviations' for the list of haloacetic acids contaminants